

GENERAL NOTES

	SERIALS	NOTES	PAGE NO.
			108

IF PROVIDED UNDER SLAB ALL UNDERGROUND CONDUIT SHALL BE 12" BELOW FINISHED GRADE.

ELECTRICAL SYMBOLS SPECIFICATIONS, NOTES

TRUE WARM & WELCOME 2300 R5